

# COVER PAGE WR#8102871



**"LOCATES MUST BE SECURED AND SOFT DIGS  
PERFORMED PRIOR TO CONSTRUCTION TO  
VERIFY DEPTHS OF FOREIGN UTILITIES"**

**SITE TO BE RESTORED TO ORIGINAL  
BETTER CONDITION AT CONCLUSION  
OF CONSTRUCTION"**


TOTAL LINEAR BORE FEET: 1800 FT

## CONSTRUCTION NOTES

- \* CENTERLINE OF BORE IS MIN 1FT WITHIN R/W. NO TRENCHING (UNLESS NOTED)
- \* EASEMENT: 10 FT IN FRONT OF PROPERTY AT ALL TX LOCATIONS (UNLESS NOTED)
- \* PRIMARY IN 1-2" HDPE MIN 36" COVER
- \* SECONDARY IN 1-2" HDPE MIN 24" MIN COVER
- \* ALL HANDHOLES ARE 30" (UNLESS NOTED)
- \* FPL TO MAINTAIN MINIMUM 12" SEPARATION FROM FOREIGN UTILITIES

## GENERAL NOTE

- \* CALL SUNSHINE @ 1-800-432-4770 48 HRS BEFORE CONSTRUCTION BEGINS
- \* THE PERMIT SHALL BE ON SITE AT ALL TIMES DURING CONSTRUCTION
- \* SIDEWALK TO BE RESTORED TO ORIGINAL CONDITION, MUST COMPLY WITH ADA (IF SIDEWALK IS AFFECTED)
- \* RESTORE AREA WITHIN 30 DAYS OF CONSTRUCTION BEFORE REQUESTING THE FINAL INSPECTION
- \* ALL MATERIALS USED AND INSTALLED WITHIN THE PUBLIC RIGHT OF WAY OR EASEMENTS SHALL BE IN ACCORDANCE WITH BROWARD COUNTY ENGINEERING DIVISION SPECIFICATION.
- \* MAINTENANCE OF TRAFFIC: THE CONTRACTOR MUST HAVE APPROVED BY BROWARD COUNTY TRAFFIC ENGINEERING DIVISION(954-587-2600) PRIOR TO SCHEDULE WORK IN THE ROAD RIGHT OF WAY.
- \* NOTICE: INSPECTION REQUIRED 24 HRS PRIOR TO COMMENCING ANY WORK IN THE PUBLIC R/W CONTACT THE BROWARD COUNTY ENGINEERING DIVISION AT 954-577-4600 FOR INSPECTION.
- \***PERMIT SET** : MUST BE ON JOBSITE AT ALL TIMES DURING CONSTRUCTION



TOWNSHIP: **48** SECTION: **20** RANGE: **43**

## DIRECTIONAL BORE IN R/W UNDERGROUND ELECTRICAL FOR SERVICE



DATE: 8/19/2019

WB: 8102871

MAP NO P0349

DWG  
NO. 1

PAGE

1